



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
Division of Water Resources-Water Supply Section
JACKSON ENVIRONMENTAL FIELD OFFICE

1625 Hollywood Drive
JACKSON, TENNESSEE 38305

PHONE (731) 512-1300

STATEWIDE 1-888-891-8332

FAX (731) 661-6283

February 18, 2014

Mr. Michael Johnson, Manager
County Wide Utility District
P. O. Box 357
Alamo, Tennessee 38001

Re: Sanitary Survey
County Wide U. D. Water System
PWSID # 0000006
Crockett County

Dear Mr. Johnson:

Pursuant to Tennessee Code Annotated, Section 68-221-707, Bobby DePriest, with the TN Division of Water Resources (DWR)-Water Supply Section, Jackson Environmental Field Office (JEFO), conducted a sanitary survey beginning February 4, 2014 of the waterworks system serving the County Wide Utility District. Your assistance during the course of the sanitary survey was very much appreciated.

Based on no deficiencies being observed at the time of this sanitary survey, this water system incurred no deduction points. Therefore, in accordance with the score calculation procedure as outlined in the *Guidance for Rating a Public Water Supply System*, your water system received a numerical rating of **100**, placing it among the State's "Approved" water supplies.

Each of your water plants were observed during normal operation and all appeared to be functioning properly as designed.